

AESM Middle School (Initial Testing)
3021 Hickory Street
St. Louis, Missouri 63104

Date of Sampling: June 19, 2016

Number of Samples Collected: 9
Number of Samples > 20 ppb: 1
Number of Samples > 10 ppb: 1

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Fountain	2nd Floor High	1.0 ppb	3.4 ppb	Priority 3
02	Fountain	2nd Floor Low	1.0 ppb	1.8 ppb	Priority 3
03	Fountain	1st Floor High	1.0 ppb	2.9 ppb	Priority 3
04	Fountain	1st Floor Low	1.0 ppb	1.4 ppb	Priority 3
05	Fountain	Room 104	1.0 ppb	14.7 ppb	Priority 2
06	Fountain	Nurse Office	1.0 ppb	24.9 ppb	Priority 1
07	Sink	Kitchen	1.0 ppb	2.8 ppb	Priority 3
08	Fountain	Outside Lunch Room High	1.0 ppb	<1.0 ppb	Priority 3
09	Fountain	Outside Lunch Room Low	1.0 ppb	<1.0 ppb	Priority 3

AESM Middle School 2nd (Follow-up Testing)
3021 Hickory Street
St. Louis, Missouri 63104

Date of Sampling: July 27, 2016

Number of Samples Collected: 1
Number of Samples > 20 ppb: 0
Number of Samples > 10 ppb: 1

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01(Re-Sample of Sample #06)	Fountain	Nurse Office	1.0 ppb	15.6 ppb	Priority 2