

**Carr Lane Middle School  
 1004 North Jefferson Avenue  
 St. Louis, Missouri 63106**

**Date of Sampling: July 25, 2016**

**Number of Samples Collected: 16  
 Number of Samples > 20 ppb: 0  
 Number of Samples > 10 ppb: 1**

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Sink	Kitchen East	1.0 ppb	1.6 ppb	Priority 3
02	Sink	Kitchen North	1.0 ppb	3.0 ppb	Priority 3
03	Fountain	Boys Restroom	1.0 ppb	< 1.0 ppb	Priority 3
04	Fountain	Girls Restroom	1.0 ppb	< 1.0 ppb	Priority 3
05	Fountain	Auditorium	1.0 ppb	< 1.0 ppb	Priority 3
06	Fountain	Near Room 107	1.0 ppb	< 1.0 ppb	Priority 3
07	Fountain	Near Room 104	1.0 ppb	< 1.0 ppb	Priority 3
08	Fountain	Near Room 125	1.0 ppb	1.5 ppb	Priority 3
09	Sink	Near Room 123	1.0 ppb	13.8 ppb	Priority 2
10	Fountain	Near Room 112	1.0 ppb	8.6 ppb	Priority 3
11	Fountain	Boys Restroom East	1.0 ppb	< 1.0 ppb	Priority 3
12	Fountain	Boys Restroom 2 <sup>nd</sup>	1.0 ppb	< 1.0 ppb	Priority 3
13	Sink	Near Room 201	1.0 ppb	1.6 ppb	Priority 3
14	Sink	Room 208	1.0 ppb	1.6 ppb	Priority 3
15	Sink	Near Room 301	1.0 ppb	2.5 ppb	Priority 3
16	Fountain	Boys Restroom 3 <sup>rd</sup> Floor	1.0 ppb	1.0 ppb	Priority 3

CONTINUED ON NEXT PAGE

**Carr Lane Middle School (Re-Sample of Fountain Near Room 123)**  
**1004 North Jefferson Avenue**  
**St. Louis, Missouri 63106**

**Date of Sampling: August 6, 2016**

**Number of Samples Collected: 1**

**Number of Samples > 20 ppb: 1**

**Number of Samples > 10 ppb: 0**

<b>Sample ID #</b>	<b>Sample Source</b>	<b>Sample Location</b>	<b>Reporting Limit</b>	<b>Result</b>	<b>Priority</b>
01(RE-Sample of Sample #09)	Fountain	Near Room 123	1.0 ppb	74.3 ppb	Priority 1