

Clay School (Initial Testing)
4041 South Broadway
St. Louis, Missouri 63118

Date of Sampling: May 24, 2016

Number of Samples Collected: 9
Number of Samples > 20 ppb: 0
Number of Samples > 10 ppb: 1

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Sink	Kitchen	1.0 ppb	< 1.0 ppb	Priority 3
02	Fountain	Near Room 024	1.0 ppb	1.6 ppb	Priority 3
03	Fountain	O/S of Gym North End	1.0 ppb	< 1.0 ppb	Priority 3
04	Fountain	Near Room 104 North	1.0 ppb	8.5 ppb	Priority 3
05	Fountain	Near Room 102 South	1.0 ppb	8.9 ppb	Priority 3
06	Fountain	Near Room 206	1.0 ppb	16.0 ppb	Priority 2
07	Fountain	Near Room 208	1.0 ppb	9.5 ppb	Priority 3
08	Fountain	O/S of Cafeteria	1.0 ppb	1.5 ppb	Priority 3
09	Fountain	O/S of Gym South End	1.0 ppb	< 1.0 ppb	Priority 3

CONTINUED ON NEXT PAGE

Clay School (Follow-up Testing)
 4041 South Broadway
 St. Louis, Missouri 63118

Date of Sampling: July 6, 2016

Number of Samples Collected: 12
 Number of Samples > 20 ppb: 3
 Number of Samples > 10 ppb: 1

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01 (Re-Sample of Sample # 03)	Fountain	O/S of Gym North End High	1.0 ppb	< 1.0 ppb	Priority 3
02 (Re-Sample of Sample # 03)	Fountain	O/S of Gym North End Low	1.0 ppb	< 1.0 ppb	Priority 3
03 (Re-Sample of Sample # 08)	Fountain	O/S of Cafeteria High	1.0 ppb	1.4 ppb	Priority 3
04 (Re-Sample of Sample # 08)	Fountain	O/S of Cafeteria Low	1.0 ppb	< 1.0 ppb	Priority 3
05 (Re-Sample of Sample #01)	Sink	Kitchen	1.0 ppb	5.3 ppb	Priority 3
06 (Re-Sample of	Fountain	Near Room 024 High	1.0 ppb	2.4 ppb	Priority 3

CONTINUED ON NEXT PAGE

Sample #02)					
07 Re-Sample of Sample #02)	Fountain	Near Room 024 Low	1.0 ppb	1.6 ppb	Priority 3
08 (Re-Sample of Sample #05)	Fountain	Near Room 102 South	1.0 ppb	43.9 ppb	Priority 1
09 (Re-Sample of Sample #04)	Fountain	Near Room 104 North	1.0 ppb	26.8 ppb	Priority 1
10 (Re-Sample of Sample #06)	Fountain	Near Room 206	1.0 ppb	116 ppb	Priority 1
11 Re-Sample of Sample #07)	Fountain	Near Room 208	1.0 ppb	17.1 ppb	Priority 2
12 (Re-Sample of Sample #09)	Fountain	O/S of Gym South End	1.0 ppb	< 1.0 ppb	Priority 3