

Fanning Middle School (Initial Site Visit)
3417 Grace Avenue
St. Louis, Missouri 63116

Date of Sampling: July 20, 2016

Number of Samples Collected: 6
Number of Samples > 20 ppb: 2
Number of Samples > 10 ppb: 1

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Fountain	2 nd Floor North	1.0 ppb	280 ppb	Priority 1
02	Fountain	2 nd Floor South	1.0 ppb	16.4 ppb	Priority 2
03	Fountain	1 st Floor North	1.0 ppb	148 ppb	Priority 1
04	Sink	Kitchen	1.0 ppb	3.9 ppb	Priority 3
05	Fountain	Gym	1.0 ppb	3.5 ppb	Priority 3
06	Fountain	Basement South	1.0 ppb	1.0 ppb	Priority 3

Fanning Middle School (Re-Sample 1st and 2nd Floor Fountains)
3417 Grace Avenue
St. Louis, Missouri 63116

Date of Sampling: July 28, 2016

Number of Samples Collected: 3
Number of Samples > 20 ppb: 3
Number of Samples > 10 ppb: 0

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01 (Re-Sample of Sample #02)	Fountain	2 nd Floor South	1.0 ppb	30.3 ppb	Priority 1
02 (Re-Sample of Sample #01)	Fountain	2 nd Floor North	1.0 ppb	61.7 ppb	Priority 1
03 (Re-Sample of Sample #03)	Fountain	1 st Floor North	1.0 ppb	28.0 ppb	Priority 1