

Gateway Middle School (Initial Site Visit)
1200 North Jefferson Avenue
St. Louis, Missouri 63106

Date of Sampling: July 6, 2016

Number of Samples Collected: 22

Number of Samples > 20 ppb: 0

Number of Samples > 10 ppb: 1

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Fountain	Near Room 161 High	1.0 ppb	< 1.0 ppb	Priority 3
02	Fountain	Near Room 161 Low	1.0 ppb	< 1.0 ppb	Priority 3
03	Fountain	Near Library High	1.0 ppb	9.1 ppb	Priority 3
04	Fountain	Near Library Low	1.0 ppb	13.0 ppb	Priority 2
05	Fountain	Near Room 138	1.0 ppb	< 1.0 ppb	Priority 3
06	Fountain	Near Room 136 High	1.0 ppb	< 1.0 ppb	Priority 3
07	Fountain	Near Room 136 Low	1.0 ppb	< 1.0 ppb	Priority 3
08	Fountain	Near Room 228 High	1.0 ppb	< 1.0 ppb	Priority 3
09	Fountain	Near Room 228 Low	1.0 ppb	< 1.0 ppb	Priority 3
10	Fountain	Near Room 226 High	1.0 ppb	< 1.0 ppb	Priority 3
11	Fountain	Near Room 226 Low	1.0 ppb	< 1.0 ppb	Priority 3
12	Fountain	Near Room 244 High	1.0 ppb	< 1.0 ppb	Priority 3
13	Fountain	Near Room 244 Low	1.0 ppb	< 1.0 ppb	Priority 3
14	Fountain	Near Room 205 High	1.0 ppb	< 1.0 ppb	Priority 3
15	Fountain	Near Room 205 Low	1.0 ppb	< 1.0 ppb	Priority 3
16	Fountain	Near Room 305 High	1.0 ppb	< 1.0 ppb	Priority 3

17	Fountain	Near Room 305 Low	1.0 ppb	< 1.0 ppb	Priority 3
18	Sink	Kitchen	1.0 ppb	< 1.0 ppb	Priority 3
19	Fountain	Cafeteria East	1.0 ppb	< 1.0 ppb	Priority 3
20	Fountain	Cafeteria East Center	1.0 ppb	< 1.0 ppb	Priority 3
21	Fountain	Cafeteria West Center	1.0 ppb	< 1.0 ppb	Priority 3
22	Fountain	Cafeteria West West	1.0 ppb	< 1.0 ppb	Priority 3

Gateway Middle School (Re-Sample Library)
1200 North Jefferson Avenue
St. Louis, Missouri 63106

Date of Sampling: July 28, 2016

Number of Samples Collected: 2

Number of Samples > 20 ppb: 1

Number of Samples > 10 ppb: 0

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01 (Re-Sample of Sample #03)	Fountain	Near Library High	1.0 ppb	< 1.0 ppb	Priority 3
02 (Re-Sample of Sample #04)	Fountain	Near Library Low	1.0 ppb	50.0 ppb	Priority 1