

**Gateway STEM High School
5101 McRee Avenue
St. Louis, Missouri 63110**

Date of Sampling: July 25, 2016

Number of Samples Collected: 27

Number of Samples > 20 ppb: 2

Number of Samples > 10 ppb: 1

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Fountain	Near Room 004	1.0 ppb	8.8 ppb	Priority 3
02	Fountain	Near Room 009	1.0 ppb	1.7 ppb	Priority 3
03	Fountain	Near Room 013	1.0 ppb	< 1.0 ppb	Priority 3
04	Sink	Room 013	1.0 ppb	5.7 ppb	Priority 3
05	Fountain	Near Room 120	1.0 ppb	< 1.0 ppb	Priority 3
06	Fountain	Gym 1 st Floor	1.0 ppb	< 1.0 ppb	Priority 3
07	Fountain	Near Room FH109	1.0 ppb	< 1.0 ppb	Priority 3
08	Sink	Room 194	1.0 ppb	5.9 ppb	Priority 3
09	Fountain	Near Room 101	1.0 ppb	1.6 ppb	Priority 3
10	Sink	Kitchen By Women RR	1.0 ppb	9.3 ppb	Priority 3
11	Sink	Kitchen North by RR	1.0 ppb	243 ppb	Priority 1
12	Sink	Kitchen Northeast	1.0 ppb	3.6 ppb	Priority 3
13	Sink	Kitchen Southeast	1.0 ppb	8.1 ppb	Priority 3
14	Sink	Kitchen Dishwasher	1.0 ppb	< 1.0 ppb	Priority 3
15	Sink	Kitchen West Cooler	1.0 ppb	5.6 ppb	Priority 3
16	Sink	Kitchen Center	1.0 ppb	12.6 ppb	Priority 2
17	Sink	Kitchen	1.0 ppb	1.9 ppb	Priority 3

18	Fountain	Cafeteria East	1.0 ppb	2.8 ppb	Priority 3
19	Fountain	Near Room 223	1.0 ppb	20.1 ppb	Priority 1
20	Fountain	Near Room 221	1.0 ppb	2.3 ppb	Priority 3
21	Fountain	Near Room 218	1.0 ppb	< 1.0 ppb	Priority 3
22	Fountain	Near Room 328	1.0 ppb	< 1.0 ppb	Priority 3
23	Fountain	Near Room 304	1.0 ppb	1.7 ppb	Priority 3
24	Fountain	Near Room 307	1.0 ppb	2.0 ppb	Priority 3
25	Fountain	Near Room 412	1.0 ppb	8.8 ppb	Priority 3
26	Fountain	Near Room 403	1.0 ppb	1.0 ppb	Priority 3
27	Fountain	Near Room 426	1.0 ppb	2.5 ppb	Priority 3

Gateway STEM High School (Re-Sample Sink)
5101 McRee Avenue
St. Louis, Missouri 63110

Date of Sampling: August 6, 2016

Number of Samples Collected: 1

Number of Samples > 20 ppb: 1

Number of Samples > 10 ppb: 0

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01 (Re-Sample of Sample #16)	Sink	Kitchen Center	1.0 ppb	85.1 ppb	Priority 1