

Henry Elementary School (Initial Site Visit)
 1220 North 10th Street
 St. Louis, Missouri 63106

Date of Sampling: June 28, 2016

Number of Samples Collected: 7
 Number of Samples > 20 ppb: 0
 Number of Samples > 10 ppb: 1

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Fountain	2 nd Floor North	1.0 ppb	1.0 ppb	Priority 3
02	Fountain	1 st Near Room 101	1.0 ppb	13.2 ppb	Priority 2
03	Fountain	1 st Floor South	1.0 ppb	7.2 ppb	Priority 3
04	Sink	Kitchen	1.0 ppb	3.8 ppb	Priority 3
05	Fountain	Basement South Low	1.0 ppb	< 1.0 ppb	Priority 3
06	Fountain	Basement North High	1.0 ppb	< 1.0 ppb	Priority 3
07	Fountain	Basement North Low	1.0 ppb	< 1.0 ppb	Priority 3

Henry Elementary School (Follow-Up Site Visit)
 1220 North 10th Street
 St. Louis, Missouri 63106

Date of Sampling: July 8, 2016

Number of Samples Collected: 8
 Number of Samples > 20 ppb: 1
 Number of Samples > 10 ppb: 1

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Fountain	2 nd Floor North	1.0 ppb	1.2 ppb	Priority 3
02 (Re-Sample of Sample #02)	Fountain	1 st Floor North	1.0 ppb	11.4 ppb	Priority 2
03 (Re-Sample of Sample #03)	Fountain	1 st Floor South	1.0 ppb	5.4 ppb	Priority 3
04	Fountain	South by Cafe	1.0 ppb	29.0 ppb	Priority 1
05 (Re-Sample of Sample #04)	Sink	Kitchen	1.0 ppb	6.8 ppb	Priority 3
06	Fountain	Gym Low	1.0 ppb	< 1.0 ppb	Priority 3
07	Fountain	Basement North North	1.0 ppb	< 1.0 ppb	Priority 3
08	Fountain	Basement North South	1.0 ppb	< 1.0 ppb	Priority 3