

Herzog Elementary School (Initial Site Visit)
5831 Pamplin Avenue
St. Louis, Missouri 63147

Date of Sampling: June 30, 2016

Number of Samples Collected: 9
Number of Samples > 20 ppb: 0
Number of Samples > 10 ppb: 1

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Fountain	2 nd Floor South	1.0 ppb	7.0 ppb	Priority 3
02	Fountain	2 nd Floor North	1.0 ppb	< 1.0 ppb	Priority 3
03	Fountain	1 st Floor Center	1.0 ppb	< 1.0 ppb	Priority 3
04	Fountain	1 st Floor South	1.0 ppb	< 1.0 ppb	Priority 3
05	Sink	Kitchen	1.0 ppb	11.3 ppb	Priority 2
06	Fountain	Basement N. Center High	1.0 ppb	< 1.0 ppb	Priority 3
07	Fountain	Basement N. Center Low	1.0 ppb	7.2 ppb	Priority 3
08	Fountain	Basement North High	1.0 ppb	< 1.0 ppb	Priority 3
09	Fountain	Basement North Low	1.0 ppb	< 1.0 ppb	Priority 3

Herzog Elementary School (Re-Sample Kitchen)
5831 Pamplin Avenue
St. Louis, Missouri 63147

Date of Sampling: July 28, 2016

Number of Samples Collected: 1
Number of Samples > 20 ppb: 0
Number of Samples > 10 ppb: 0

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01(Re-Sample of Sample #05)	Sink	Kitchen	1.0 ppb	4.1 ppb	Priority 3