

**Hickey Elementary School (Initial Site Visit)**  
**3111 Cora Avenue**  
**St. Louis, Missouri 63115**

**Date of Sampling: July 7, 2016**

**Number of Samples Collected: 10**  
**Number of Samples > 20 ppb: 0**  
**Number of Samples > 10 ppb: 0**

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Fountain	3 <sup>rd</sup> Floor North	1.0 ppb	1.7 ppb	Priority 3
02	Fountain	2 <sup>nd</sup> Floor South	1.0 ppb	1.0 ppb	Priority 3
03	Fountain	2 <sup>nd</sup> Floor North	1.0 ppb	3.7 ppb	Priority 3
04	Fountain	1 <sup>st</sup> Floor NE North	1.0 ppb	< 1.0 ppb	Priority 3
05	Fountain	1 <sup>st</sup> Floor NE South	1.0 ppb	2.1 ppb	Priority 3
06	Sink	Kitchen	1.0 ppb	9.9 ppb	Priority 3
07	Fountain	Gym	1.0 ppb	< 1.0 ppb	Priority 3
08	Fountain	1 <sup>st</sup> Floor South – South	1.0 ppb	< 1.0 ppb	Priority 3
09	Fountain	1 <sup>st</sup> Floor South – Center	1.0 ppb	< 1.0 ppb	Priority 3
10	Fountain	1 <sup>st</sup> Floor South - North	1.0 ppb	< 1.0 ppb	Priority 3

**Hickey Elementary School (Re-Test Kitchen)**  
**3111 Cora Avenue**  
**St. Louis, Missouri 63115**

**Date of Sampling: July 28, 2016**

**Number of Samples Collected: 1**  
**Number of Samples > 20 ppb: 1**  
**Number of Samples > 10 ppb: 0**

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01 (Re-Sample of Sample #06)	Sink	Kitchen	1.0 ppb	31.8 ppb	Priority 1