

**Lexington Middle School
5030 Lexington Avenue
St. Louis, Missouri 63115**

Date of Sampling: June 30, 2016

Number of Samples Collected: 9

Number of Samples > 20 ppb: 0

Number of Samples > 10 ppb: 0

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Fountain	1 st Floor West High	1.0 ppb	< 1.0 ppb	Priority 3
02	Fountain	1 st Floor West Low	1.0 ppb	2.5 ppb	Priority 3
03	Sink	Kitchen	1.0 ppb	2.8 ppb	Priority 3
04	Fountain	Gym	1.0 ppb	3.4 ppb	Priority 3
05	Fountain	1 st Floor East High	1.0 ppb	< 1.0 ppb	Priority 3
06	Fountain	1 st Floor East Low	1.0 ppb	2.3 ppb	Priority 3
07	Fountain	2 nd Floor West High	1.0 ppb	< 1.0 ppb	Priority 3
08	Fountain	2 nd Floor West Low	1.0 ppb	< 1.0 ppb	Priority 3
09	Fountain	2 nd Floor East	1.0 ppb	< 1.0 ppb	Priority 3