

Lyon @ Blow Elementary School
516 Loughborough
St. Louis, Missouri 63111
Date of Sampling: July 06, 2016

Number of Samples Collected: 8
Number of Samples > 20 ppb: 0
Number of Samples > 10 ppb: 0

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Fountain	2nd Floor West	1.0 ppb	1.4 ppb	Priority 3
02	Fountain	2nd Floor East	1.0 ppb	2.5 ppb	Priority 3
03	Fountain	1st Floor East	1.0 ppb	2.4 ppb	Priority 3
04	Fountain	1st Floor West	1.0 ppb	< 1.0 ppb	Priority 3
05	Fountain	Gym Low	1.0 ppb	< 1.0 ppb	Priority 3
06	Fountain	Gym High	1.0 ppb	< 1.0 ppb	Priority 3
07	Sink	Kitchen	1.0 ppb	7.1 ppb	Priority 3
08	Fountain	Cafeteria High	1.0 ppb	2.0 ppb	Priority 3