

**Madison School
1118 South 8th Street
St. Louis, Missouri 63104**

Date of Sampling: August 5, 2016

Number of Samples Collected: 18

Number of Samples > 20 ppb: 0

Number of Samples > 10 ppb: 0

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Fountain	Near Room 305 High	1.0 ppb	< 1.0 ppb	Priority 3
02	Fountain	Near Room 305 Low	1.0 ppb	< 1.0 ppb	Priority 3
03	Fountain	Near Room 303 High	1.0 ppb	< 1.0 ppb	Priority 3
04	Fountain	Near Room 303 Low	1.0 ppb	< 1.0 ppb	Priority 3
05	Fountain	Near Room 203 High	1.0 ppb	< 1.0 ppb	Priority 3
06	Fountain	Near Room 203 Low	1.0 ppb	< 1.0 ppb	Priority 3
07	Fountain	Near Room 205 High	1.0 ppb	< 1.0 ppb	Priority 3
08	Fountain	Near Room 205 Low	1.0 ppb	< 1.0 ppb	Priority 3
09	Fountain	Near Room 106 high	1.0 ppb	< 1.0 ppb	Priority 3
10	Fountain	Near Room 106 Low	1.0 ppb	< 1.0 ppb	Priority 3
11	Fountain	Near Room 104 High	1.0 ppb	< 1.0 ppb	Priority 3
12	Fountain	Near Room 104 Low	1.0 ppb	< 1.0 ppb	Priority 3
13	Fountain	Cafeteria High	1.0 ppb	< 1.0 ppb	Priority 3
14	Fountain	Cafeteria Low	1.0 ppb	< 1.0 ppb	Priority 3
15	Sink	Kitchen Large	1.0 ppb	< 1.0 ppb	Priority 3
16	Sink	Kitchen Small	1.0 ppb	2.2 ppb	Priority 3

17	Fountain	Basement Near Elevator	1.0 ppb	< 1.0 ppb	Priority 3
18	Fountain	Teacher's Lounge	1.0 ppb	< 1.0 ppb	Priority 3