

**Mann Elementary School
4047 Juniata Street
St. Louis, Missouri 63116**

Date of Sampling: July 1, 2016

Number of Samples Collected: 8

Number of Samples > 20 ppb: 0

Number of Samples > 10 ppb: 1

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Fountain	1st Floor West	1.0 ppb	3.1 ppb	Priority 3
02	Fountain	1st Floor East Low	1.0 ppb	1.5 ppb	Priority 3
03	Fountain	1st Floor East High	1.0 ppb	13.4 ppb	Priority 2
04	Fountain	Gym High	1.0 ppb	< 1.0 ppb	Priority 3
05	Fountain	Gym Low	1.0 ppb	< 1.0 ppb	Priority 3
06	Fountain	Basement West High	1.0 ppb	9.1 ppb	Priority 3
07	Fountain	Basement West Low	1.0 ppb	4.4 ppb	Priority 3
08	Sink	Kitchen	1.0 ppb	3.9 ppb	Priority 3