

**Meramec Elementary School (Initial Site Visit)**  
**2745 Meramec Street**  
**St. Louis, Missouri 63118**

**Date of Sampling: June 26, 2016**

**Number of Samples Collected: 6**

**Number of Samples > 20 ppb: 0**

**Number of Samples > 10 ppb: 2**

<b>Sample ID #</b>	<b>Sample Source</b>	<b>Sample Location</b>	<b>Reporting Limit</b>	<b>Result</b>	<b>Priority</b>
01	Sink	Kitchen	1.0 ppb	14.5 ppb	Priority 2
02	Fountain	Gym East High	1.0 ppb	< 1.0 ppb	Priority 3
03	Fountain	Gym East Low	1.0 ppb	4.8 ppb	Priority 3
04	Fountain	Gym West High	1.0 ppb	< 1.0 ppb	Priority 3
05	Fountain	Gym West Low	1.0 ppb	< 1.0 ppb	Priority 3
06	Fountain	1 <sup>st</sup> Floor East	1.0 ppb	12.0 ppb	Priority 2

**Meramec Elementary School 2<sup>nd</sup> (Follow-Up Site Visit)**  
**2745 Meramec Street**  
**St. Louis, Missouri 63118**

**Date of Sampling: July 6, 2016**

**Number of Samples Collected: 10**

**Number of Samples > 20 ppb: 1**

**Number of Samples > 10 ppb: 2**

<b>Sample ID #</b>	<b>Sample Source</b>	<b>Sample Location</b>	<b>Reporting Limit</b>	<b>Result</b>	<b>Priority</b>
01	Fountain	2nd Floor West	1.0 ppb	9.6 ppb	Priority 3
02	Fountain	2nd Floor East	1.0 ppb	6.4 ppb	Priority 3
03 (Re Sample of Sample #06)	Fountain	1st Floor East	1.0 ppb	16.3 ppb	Priority 2
04 (Re Sample of Sample #01)	Sink	Kitchen	1.0 ppb	25.3 ppb	Priority 1
05 (Re Sample of Sample #03)	Fountain	Gym East Low	1.0 ppb	1.7 ppb	Priority 3
06 (Re-Sample of Sample #02)	Fountain	Gym East High	1.0 ppb	14.7 ppb	Priority 2
07	Fountain	Gym East - West Low	1.0 ppb	2.0 ppb	Priority 3
08 (Re Sample of Sample #05)	Fountain	Gym West - East Low	1.0 ppb	< 1.0 ppb	Priority 3
09 (RE-Sample of Sample #04)	Fountain	Gym West - East High	1.0 ppb	< 1.0 ppb	Priority 3

10	Fountain	Gym West Low	1.0 ppb	< 1.0 ppb	Priority 3
----	----------	-----------------	---------	-----------	------------

**Meramec Elementary School (Kitchen By-Pass)**  
**2745 Meramec Street**  
**St. Louis, Missouri 63118**  
**Date of Sampling: July 26, 2016**

**Number of Samples Collected: 1**  
**Number of Samples > 20 ppb: 0**  
**Number of Samples > 10 ppb: 0**

<b>Sample ID #</b>	<b>Sample Source</b>	<b>Sample Location</b>	<b>Reporting Limit</b>	<b>Result</b>	<b>Priority</b>
01	Sink	Kitchen	1.0 ppb	7.3 ppb	Priority 3