

Clyde C. Miller Career Academy High School (Initial Testing)
1000 North Grand Boulevard
St. Louis, Missouri 63106

Date of Sampling: July 25, 2016

Number of Samples Collected: 25
Number of Samples > 20 ppb: 3
Number of Samples > 10 ppb: 3

| Sample ID # | Sample Source | Sample Location | Reporting Limit | Result | Priority |
|--------------------|----------------------|-------------------------|------------------------|---------------|-----------------|
| 01 | Sink | Kitchen North | 1.0 ppb | 12.5 ppb | Priority 2 |
| 02 | Sink | Kitchen Center | 1.0 ppb | 45.9 ppb | Priority 1 |
| 03 | Sink | Kitchen South | 1.0 ppb | 14.1 ppb | Priority 2 |
| 04 | Sink | Hand Wash North | 1.0 ppb | 4.2 ppb | Priority 3 |
| 05 | Sink | Hand Wash South | 1.0 ppb | 4.6 ppb | Priority 3 |
| 06 | Sink | Serving North | 1.0 ppb | 3.5 ppb | Priority 3 |
| 07 | Sink | Serving South | 1.0 ppb | 11.8 ppb | Priority 2 |
| 08 | Fountain | Cafeteria | 1.0 ppb | < 1.0 ppb | Priority 3 |
| 09 | Fountain | Near Room 160 | 1.0 ppb | < 1.0 ppb | Priority 3 |
| 10 | Sink | Lounge | 1.0 ppb | 2.8 ppb | Priority 3 |
| 11 | Fountain | Gymnasium | 1.0 ppb | < 1.0 ppb | Priority 3 |
| 12 | Sink | Room 127 W. Wall North | 1.0 ppb | 3.9 ppb | Priority 3 |
| 13 | Sink | Room 127 W. Wall South | 1.0 ppb | 6.6 ppb | Priority 3 |
| 14 | Sink | Room 127 Dishwasher | 1.0 ppb | < 1.0 ppb | Priority 3 |
| 15 | Sink | Room 127 Center Aisle N | 1.0 ppb | 6.0 ppb | Priority 3 |
| 16 | Sink | Room 127 Center Aisle S | 1.0 ppb | 55.1 ppb | Priority 1 |
| 17 | Sink | Room 127 North | 1.0 ppb | 22.6 ppb | Priority 1 |

| | | | | | |
|----|----------|-----------------------|---------|-----------|------------|
| 18 | Sink | Room 127 East Wall | 1.0 ppb | 3.1 ppb | Priority 3 |
| 19 | Sink | Room 127 South | 1.0 ppb | 2.0 ppb | Priority 3 |
| 20 | Sink | Room 125 | 1.0 ppb | < 1.0 ppb | Priority 3 |
| 21 | Fountain | Near Room 112 | 1.0 ppb | < 1.0 ppb | Priority 3 |
| 22 | Fountain | Near Room 245 | 1.0 ppb | < 1.0 ppb | Priority 3 |
| 23 | Fountain | Near Room 223 | 1.0 ppb | < 1.0 ppb | Priority 3 |
| 24 | Sink | Room 208 | 1.0 ppb | 5.2 ppb | Priority 3 |
| 25 | Fountain | Near Room 212 | 1.0 ppb | < 1.0 ppb | Priority 3 |

Clyde C. Miller Career Academy High School (Re-Sample Kitchen Sink)
1000 North Grand Boulevard
St. Louis, Missouri 63106

Date of Sampling: August 6, 2016

Number of Samples Collected: 3

Number of Samples > 20 ppb: 0

Number of Samples > 10 ppb: 0

| Sample ID # | Sample Source | Sample Location | Reporting Limit | Result | Priority |
|------------------------------|----------------------|------------------------|------------------------|---------------|-----------------|
| 01 (Re-Sample of Sample #01) | Sink | Kitchen North | 1.0 ppb | 5.0 ppb | Priority 3 |
| 02 (Re-Sample of Sample #03) | Sink | Kitchen South | 1.0 ppb | 1.0 ppb | Priority 3 |
| 03 (Re-Sample of Sample #07) | Sink | Serving South | 1.0 ppb | 4.9 ppb | Priority 3 |