

**Nahad Chapman School  
1530 South Grand  
St. Louis, Missouri 63104**

**Date of Sampling: August 5, 2016**

**Number of Samples Collected: 18**

**Number of Samples > 20 ppb: 1**

**Number of Samples > 10 ppb: 2**

<b>Sample ID #</b>	<b>Sample Source</b>	<b>Sample Location</b>	<b>Reporting Limit</b>	<b>Result</b>	<b>Priority</b>
01	Fountain	Near Room 106	1.0 ppb	8.9 ppb	Priority 3
02	Fountain	Near Room 107	1.0 ppb	< 1.0 ppb	Priority 3
03	Fountain	Multi-Purpose Room	1.0 ppb	22.9 ppb	Priority 1
04	Fountain	Nurse Office	1.0 ppb	3.8 ppb	Priority 3
05	Sink	Kitchen Prep	1.0 ppb	< 1.0 ppb	Priority 3
06	Sink	Kitchen	1.0 ppb	1.2 ppb	Priority 3
07	Fountain	Kitchen Near Shut Off	1.0 ppb	< 1.0 ppb	Priority 3
08	Fountain	Near Room 310 Multi Front Bldg 3	1.0 ppb	3.0 ppb	Priority 3
09	Fountain	Near Room 310 Single Front Bldg 3	1.0 ppb	< 1.0 ppb	Priority 3
10	Sink	Room 301 Bldg 3	1.0 ppb	6.6 ppb	Priority 3
11	Fountain	Near Room 307 Bldg 3	1.0 ppb	< 1.0 ppb	Priority 3

12	Sink	Room 305 Bldg 3	1.0 ppb	6.1 ppb	Priority 3
13	Sink	Room 304 Bldg 3	1.0 ppb	12.4 ppb	Priority 2
14	Sink	Room 308 Bldg 3	1.0 ppb	3.1 ppb	Priority 3
15	Sink	Room 303 Bldg 3	1.0 ppb	11.0 ppb	Priority 2
16	Sink	Room 300 Bldg 3	1.0 ppb	5.6 ppb	Priority 3
17	Fountain	Near Room 203 Multi Front Bldg 2	1.0 ppb	< 1.0 ppb	Priority 3
18	Fountain	Near Room 203 Single Front Bldg 2	1.0 ppb	< 1.0 ppb	Priority 3