

**Nance Elementary School  
8959 Riverview Boulevard  
St. Louis, Missouri 63147**

**Date of Sampling: June 30, 2016**

**Number of Samples Collected: 9**

**Number of Samples > 20 ppb: 0**

**Number of Samples > 10 ppb: 0**

<b>Sample ID #</b>	<b>Sample Source</b>	<b>Sample Location</b>	<b>Reporting Limit</b>	<b>Result</b>	<b>Priority</b>
01	Fountain	2 <sup>nd</sup> Floor East High	1.0 ppb	< 1.0 ppb	Priority 3
02	Fountain	2 <sup>nd</sup> Floor East Low	1.0 ppb	< 1.0 ppb	Priority 3
03	Fountain	2 <sup>nd</sup> Floor West	1.0 ppb	< 1.0 ppb	Priority 3
04	Sink	Kitchen	1.0 ppb	2.4 ppb	Priority 3
05	Fountain	Cafeteria High	1.0 ppb	< 1.0 ppb	Priority 3
06	Fountain	Cafeteria Low	1.0 ppb	< 1.0 ppb	Priority 3
07	Fountain	Gym	1.0 ppb	< 1.0 ppb	Priority 3
08	Fountain	1 <sup>st</sup> Floor East High	1.0 ppb	< 1.0 ppb	Priority 3
09	Fountain	1 <sup>st</sup> Floor East Low	1.0 ppb	< 1.0 ppb	Priority 3