

**Northwest High School
5140 Riverview Boulevard
St. Louis, Missouri 63120**

Date of Sampling: July 27, 2016

Number of Samples Collected: 16

Number of Samples > 20 ppb: 4

Number of Samples > 10 ppb: 1

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Fountain	Room 212	1.0 ppb	1.3 ppb	Priority 3
02	Sink	Faculty Lounge	1.0 ppb	2.7 ppb	Priority 3
03	Fountain	Room 113	1.0 ppb	< 1.0 ppb	Priority 3
04	Fountain	Ground Floor Girls Restroom	1.0 ppb	< 1.0 ppb	Priority 3
05	Sink	Kitchen North East	1.0 ppb	21.3 ppb	Priority 1
06	Sink	Kitchen Central East	1.0 ppb	9.5 ppb	Priority 3
07	Sink	Kitchen South East	1.0 ppb	97.1 ppb	Priority 1
08	Sink	Kitchen North West	1.0 ppb	2.4 ppb	Priority 3
09	Sink	Kitchen Central West	1.0 ppb	1.4 ppb	Priority 3
10	Sink	Kitchen Southern Back	1.0 ppb	202 ppb	Priority 1
11	Sink	Kitchen North Central	1.0 ppb	7.7 ppb	Priority 3
12	Fountain	Auditorium	1.0 ppb	< 1.0 ppb	Priority 3
13	Fountain	Girls Locker Room	1.0 ppb	< 1.0 ppb	Priority 3
14	Fountain	Boys Locker Room	1.0 ppb	7.1 ppb	Priority 3
15	Fountain	PE Storage Room	1.0 ppb	109 ppb	Priority 1
16	Fountain	Girls Gym	1.0 ppb	15.5 ppb	Priority 2

**Northwest High School (Re-Sample Girls Gym Fountain)
5140 Riverview Boulevard
St. Louis, Missouri 63120**

Date of Sampling: August 6, 2016

Number of Samples Collected: 6

Number of Samples > 20 ppb: 0

Number of Samples > 10 ppb: 0

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01 (Re-Sample of Sample #16)	Fountain	Girls Gym	1.0 ppb	< 1.0 ppb	Priority 3