

**Oak Hill Elementary School  
4300 Morganford Road  
St. Louis, Missouri 63116**

**Date of Sampling: July 1, 2016**

**Number of Samples Collected: 8**

**Number of Samples > 20 ppb: 0**

**Number of Samples > 10 ppb: 0**

<b>Sample ID #</b>	<b>Sample Source</b>	<b>Sample Location</b>	<b>Reporting Limit</b>	<b>Result</b>	<b>Priority</b>
01	Fountain	2nd Floor North	1.0 ppb	1.2 ppb	Priority 3
02	Fountain	2nd Floor South	1.0 ppb	3.0 ppb	Priority 3
03	Fountain	1st Floor South	1.0 ppb	< 1.0 ppb	Priority 3
04	Fountain	1st Floor North	1.0 ppb	< 1.0 ppb	Priority 3
05	Fountain	Basement North	1.0 ppb	< 1.0 ppb	Priority 3
06	Sink	Kitchen	1.0 ppb	< 1.0 ppb	Priority 3
07	Fountain	Gym High	1.0 ppb	2.9 ppb	Priority 3
08	Fountain	Gym Low	1.0 ppb	< 1.0 ppb	Priority 3