

Roosevelt High School (Initial Site Visit)
3230 Hartford Avenue
St. Louis, Missouri 63118

Date of Sampling: July 19, 2016

Number of Samples Collected: 15

Number of Samples > 20 ppb: 1

Number of Samples > 10 ppb: 1

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Fountain	3 rd Floor West	1.0 ppb	4.5 ppb	Priority 3
02	Fountain	3 rd Floor East	1.0 ppb	2.0 ppb	Priority 3
03	Fountain	2 nd Floor East	1.0 ppb	< 1.0 ppb	Priority 3
04	Fountain	2 nd Floor Center East	1.0 ppb	2.5 ppb	Priority 3
05	Fountain	1 st Floor Center West	1.0 ppb	1.8 ppb	Priority 3
06	Fountain	1 st Floor Center East	1.0 ppb	2.1 ppb	Priority 3
07	Fountain	1 st Floor East Low	1.0 ppb	< 1.0 ppb	Priority 3
08	Fountain	1 st Floor South East	1.0 ppb	72.3 ppb	Priority 1
09	Fountain	Basement East High	1.0 ppb	< 1.0 ppb	Priority 3
10	Fountain	Basement East Low	1.0 ppb	< 1.0 ppb	Priority 3
11	Sink	Kitchen	1.0 ppb	10.3 ppb	Priority 2
12	Fountain	Basement South West	1.0 ppb	< 1.0 ppb	Priority 3
13	Fountain	Basement West	1.0 ppb	< 1.0 ppb	Priority 3
14	Fountain	Basement Center East	1.0 ppb	< 1.0 ppb	Priority 3
15	Fountain	Basement Center West	1.0 ppb	< 1.0 ppb	Priority 3

Roosevelt High School (Follow-Up Site Visit)
3230 Hartford Avenue
St. Louis, Missouri 63118

Date of Sampling: July 27, 2016

Number of Samples Collected: 4

Number of Samples > 20 ppb: 2

Number of Samples > 10 ppb: 0

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Sink	Kitchen East	1.0 ppb	4.4 ppb	Priority 3
02	Sink	Kitchen Central East	1.0 ppb	94.2 ppb	Priority 1
03	Sink	Kitchen Central West	1.0 ppb	< 1.0 ppb	Priority 3
04	Sink	Kitchen West	1.0 ppb	20.2 ppb	Priority 1