

Vashon High School (Excluding PIIP)
3035 Cass Avenue
St. Louis, Missouri 63106

Date of Sampling: July 26, 2016

Number of Samples Collected: 32

Number of Samples > 20 ppb: 1

Number of Samples > 10 ppb: 4

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Fountain	Near Room B237	1.0 ppb	< 1.0 ppb	Priority 3
02	Fountain	Near Room C244	1.0 ppb	< 1.0 ppb	Priority 3
03	Fountain	Near Room E233	1.0 ppb	< 1.0 ppb	Priority 3
04	Sink	East Teachers' Lounge	1.0 ppb	< 1.0 ppb	Priority 3
05	Fountain	Near Room F240	1.0 ppb	< 1.0 ppb	Priority 3
06	Fountain	Near Room B137	1.0 ppb	< 1.0 ppb	Priority 3
07	Sink	Central Teachers' Lounge	1.0 ppb	1.7 ppb	Priority 3
08	Fountain	Near Room 0140	1.0 ppb	< 1.0 ppb	Priority 3
09	Sink	Kitchen SE Serving Line	1.0 ppb	39.1 ppb	Priority 1
10	Sink	Kitchen East Serving Line	1.0 ppb	16.6 ppb	Priority 2
11	Sink	Kitchen North Serving Line	1.0 ppb	8.2 ppb	Priority 3
12	Sink	Kitchen West Serving Line	1.0 ppb	13.9 ppb	Priority 2
13	Sink	Kitchen SW Serving Line	1.0 ppb	11.3 ppb	Priority 2
14	Sink	Kitchen	1.0 ppb	8.4 ppb	Priority 3

15	Sink	Kitchen NW Serving Line Wall	1.0 ppb	2.2 ppb	Priority 3
16	Sink	Kitchen NE Serving Line Wall	1.0 ppb	< 1.0 ppb	Priority 3
17	Sink	Kitchen East Serving Line Wall	1.0 ppb	17.1 ppb	Priority 2
18	Sink	Kitchen SW Prep Area	1.0 ppb	1.0 ppb	Priority 3
19	Sink	Kitchen NW Prep Area	1.0 ppb	< 1.0 ppb	Priority 3
20	Sink	Kitchen North Prep	1.0 ppb	2.4 ppb	Priority 3
21	Sink	Kitchen East Prep Area	1.0 ppb	< 1.0 ppb	Priority 3
22	Sink	Kitchen East Wall	1.0 ppb	< 1.0 ppb	Priority 3
23	Sink	Kitchen West Wall Dishwashing	1.0 ppb	2.5 ppb	Priority 3
24	Sink	Kitchen North Wall Dishwashing	1.0 ppb	7.8 ppb	Priority 3
25	Sink	Kitchen NW Wall Dishwashing	1.0 ppb	3.7 ppb	Priority 3
26	Sink	Kitchen SW Wall Dishwashing	1.0 ppb	2.1 ppb	Priority 3
27	Fountain	Near Room E133	1.0 ppb	< 1.0 ppb	Priority 3
28	Sink	East Teachers' Lounge	1.0 ppb	< 1.0 ppb	Priority 3
29	Fountain	Near Room F146	1.0 ppb	< 1.0 ppb	Priority 3
30	Fountain	Gym 2 nd Floor North	1.0 ppb	< 1.0 ppb	Priority 3
31	Fountain	Gym 2 nd Floor East	1.0 ppb	< 1.0 ppb	Priority 3
32	Fountain	Near Room G032	1.0 ppb	< 1.0 ppb	Priority 3

Vashon High School (Re-Sample Sinks)
3035 Cass Avenue
St. Louis, Missouri 63106

Date of Sampling: August 8, 2016

Number of Samples Collected: 4

Number of Samples > 20 ppb: 1

Number of Samples > 10 ppb: 0

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01 (Re-Sample of Sample #10)	Sink	Kitchen East Serving Line	1.0 ppb	21.2 ppb	Priority 1
02 (Re-Sample of Sample #12)	Sink	Kitchen West Serving Line	1.0 ppb	7.8 ppb	Priority 3
03 (Re-Sample of Sample #13)	Sink	Kitchen SW Serving Line	1.0 ppb	6.4 ppb	Priority 3
04 (Re-Sample of Sample #17)	Sink	Kitchen East Serving Line Wall	1.0 ppb	5.0 ppb	Priority 3