

Beaumont High School
3836 Natural Bridge Avenue
St. Louis, Missouri 63107

Date of Sampling: July 25, 2016

Number of Samples Collected: 19

Number of Samples > 20 ppb: 4

Number of Samples > 10 ppb: 1

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Sink	Kitchen – West	1.0 ppb	< 1.0 ppb	Priority 3
02	Sink	Kitchen – East	1.0 ppb	< 1.0 ppb	Priority 3
03	Sink	Kitchen – Hand Wash	1.0 ppb	1.7 ppb	Priority 3
04	Fountain	Cafeteria	1.0 ppb	1.0 ppb	Priority 3
05	Fountain	Near Stair 5	1.0 ppb	1.2 ppb	Priority 3
06	Fountain	Near Custodian Office	1.0 ppb	1.9 ppb	Priority 3
07	Fountain	Near Room 028	1.0 ppb	9.1 ppb	Priority 3
08	Fountain	Near Room 005	1.0 ppb	< 1.0 ppb	Priority 3
09	Fountain	Near Room 105	1.0 ppb	< 1.0 ppb	Priority 3
10	Fountain	Near Room 121	1.0 ppb	1.2 ppb	Priority 3
11	Fountain	Near Room 105	1.0 ppb	< 1.0 ppb	Priority 3
12	Fountain	Near Room 211	1.0 ppb	< 1.0 ppb	Priority 3
13	Fountain	Near Room 213	1.0 ppb	19.4 ppb	Priority 2
14	Fountain	Near Room 215	1.0 ppb	40.7 ppb	Priority 1
15	Fountain	Near Room 221	1.0 ppb	< 1.0 ppb	Priority 3
16	Fountain	Near Room 318	1.0 ppb	2.7 ppb	Priority 3

17	Fountain	Near Room 324	1.0 ppb	54.7 ppb	Priority 1
18	Fountain	Near Room 325	1.0 ppb	154 ppb	Priority 1
19	Fountain	Near Room 311	1.0 ppb	35.1 ppb	Priority 1